



Temporary Stabilized Track out Pad with Mirafi 601 and 3" D50 rock !5ft x 30 ft

Temporary fence with lockable gate

Protect 2 storm water inlet boxes with drop-in style sediment bags on Heritage Way

Back Cut Sidewalk for Sediment Control

Drainage Berm

Limits of Disturbance Traffic Candles Sticks on 6 ft centers High Visible safety fence and

Phase 1 SWPPP

Phase II SWPPP will be submitted when West entrance is established

- NOTES:
1. DEMOLISH EXISTING CONCRETE SLAB/FOUNDATION AND DISPOSE MATERIAL OFFSITE AT AN APPROVED LANDFILL.
 2. POT HOLE EXISTING 18-INCH RCP PIPE STUB TO DETERMINE PIPE LOCATION AND INVERT.
 3. CONTRACTOR SHALL ADJUST BURIED EXISTING HDPE AND CUT TO LENGTH REQUIRED. CONNECT EXISTING HDPE TO NEW DUCTILE IRON PIPE WITH ROMAC ALPHA RESTRAINED JOINT COUPLING, OR RESTRAINED HDPE BELL MJ ADAPTER, OR APPROVED EQUAL.
 4. CONTRACTOR SHALL BACKFILL AROUND WELL HOUSE WITH SUITABLE NATIVE MATERIAL AS REQUIRED TO PROVIDE ADEQUATE COVER OVER PIPES AND FITTINGS AS SHOWN ON DRAWING DETAILS, AND COMPACT TO 90% MAX DRY DENSITY PER ASTM D-1557. MAX BACKFILL SLOPE SHALL BE 2:1 (HORIZONTAL:VERTICAL). BACKFILL UNDER CONCRETE STEPS AND PAD WITH SUITABLE NATIVE MATERIAL AND COMPACT TO 95% MAX DRY DENSITY PER ASTM D-1557.
 5. INSTALL APPROXIMATELY 20 FEET OF 12-INCH DI CLASS 350 PIPE. INSTALL MJ CAP. RESTRAIN ALL JOINTS.

ACCEPTED FOR CONSTRUCTION!
ACCEPTANCE DOES NOT GUARANTEE THE CORRECTNESS OR COMPLETENESS OF THE PLANS OR THAT THEY MEET ALL CITY REQUIREMENTS AND STANDARDS.

MAR 05 2018

THE CITY MAY REQUIRE FIELD MODIFICATION TO RECTIFY ANY POSSIBLE DEFICIENCIES.

SIGNED *Michael J. ...*



COORDINATE TABLE

POINT NUMBER	NORTHING	EASTING	ELEVATION	DESCRIPTION
1	7,341,934.10	1,524,963.11	4,522.00	FG WELL HOUSE CORNER*
2	7,341,938.29	1,524,960.27	4,522.00	FG WELL HOUSE CORNER*
3	7,341,928.48	1,524,971.23	4,521.73	FG WELL HOUSE CORNER*
4	7,341,944.30	1,524,954.07	4,522.00	FG WELL HOUSE CORNER*
5	7,341,929.66	1,524,964.05	4,521.66	FG DRAIN BOX
6	7,341,932.82	1,524,960.62	4,521.24	FG DRAIN BOX
7	7,341,935.76	1,524,963.33	4,522.00	FG DRAIN BOX
8	7,341,932.60	1,524,966.76	4,521.73	FG DRAIN BOX
9	7,341,957.76	1,524,968.75	4,520.83	EDGE OF SIDEWALK
10	7,341,953.69	1,524,973.16	4,521.05	EDGE OF SIDEWALK
11	7,341,949.85	1,524,977.33	4,521.23	EDGE OF SIDEWALK
12	7,341,943.08	1,524,984.68	4,521.90	EDGE OF SIDEWALK

NOTE: * COORDINATE IS TO OUTSIDE CORNER.